

ASCS Certification Practice Test Questions

Disclaimer

NADCA has developed this short list of practice test questions to give candidates a general idea of the common format of typical questions included in the ASCS Certification exam. Please note that the following questions are not actual test questions used in the ASCS exam. No representations or warranties are made by NADCA that completing this practice test will assure candidates of passing the ASCS certification exam. ***Candidates are encouraged to review the ASCS Candidates Guide and take the time to review recommended reference materials prior to taking the ASCS exam.***

1. According to the NADCA ACR Standard, it is recommended that HVAC systems in healthcare facilities should be visually inspected for cleanliness at a minimum inspection interval of
 - A. 1 year.
 - B. 6 months.
 - C. 2 years.
 - D. 2.5 years.

2. What components would an ASCS expect to find in a fan coil unit?
 - A. Diffuser, damper and grill
 - B. Blower, coil and filter
 - C. Blower, valve and filter
 - D. Damper, compressor and evaporator coil

3. According to SMACNA Duct Cleanliness for New Construction Guidelines, how many general levels of cleanliness are recommended for typical duct installations?
 - A. One
 - B. Two
 - C. Three
 - D. Four

4. According to the NADCA ACR Standard, it is recommended that porous materials with biological growth be
 - A. treated.
 - B. removed.
 - C. vacuumed.
 - D. encapsulated.

5. To be considered clean by the NADCA Vacuum Test, the net weight of the debris calibrated on the filter media must not exceed:
 - A. 0.75 mg/100 cm²
 - B. 0.85 mg/100 cm²
 - C. 1.00 mg/100 cm²
 - D. 1.02 mg/100 cm²

Answers:

1-A, 2-B, 3-C, 4-B, 5-A